



APPLICATION SPECIFICATIONS			
APPLICATION	FLUID BED DRYER ASPIRATION		
PRODUCT	FLOCK	LOADING	UNKNOWN
AIR VOLUME	6,000 ACFM	DESIGN RATING	-2.7\" W.C.
AIR TO MEDIA RATIO	N/A	SQ. FT. CLOTH AREA	N/A
OPERATING TEMP	200\" F	ALTITUDE	394 FT
CAN VELOCITY	N/A	INTERSTITIAL VELOCITY	N/A
COMPRESSED AIR	N/A	SCFM	N/A
CONTROL POWER	N/A	MOTOR POWER	N/A
WEIGHT	MFG: 1,320 LBS	COMPONENT: N/A	TOTAL: 1,320 LBS
MATERIAL OF CONSTRUCTION			
CAP/GAS:	#10 GA CARBON STEEL	DAP/PRODUCT:	#10 GA CARBON STEEL
SUPPORTS:	CARBON STEEL	LADDER:	N/A
HOPPER:	#10 GA CARBON STEEL	TUBE SHEET:	N/A
ROOF:	N/A	WALKING SURFACE:	N/A
MATERIAL FINISHES			
INTERIOR CAP PAINT:	NONE		
EXTERIOR CAP PAINT:	PRIMED AND PAINTED - KEM 400 - INDUSTRIAL WHITE		
INTERIOR DAP PAINT:	NONE		
EXTERIOR DAP PAINT:	PRIMED AND PAINTED - KEM 400 - INDUSTRIAL WHITE		
PLAT./LADD. PAINT:	N/A		
STRUCT. SUPP. PAINT:	N/A		
INTERIOR CAP WELDS:	STITCHED		
EXTERIOR CAP WELDS:	CONTINUOUS		
INTERIOR DAP WELDS:	STITCHED		
EXTERIOR DAP WELDS:	CONTINUOUS		
SPECIAL NOTES:			

(1) UNITS REQUIRED

REV1	UPDATES PER CUSTOMER	CAF	10/12/15
REV2	UPDATES PER CUSTOMER	CAF	10/13/15
REV3	GUSSETS, MANWAY, CROSSBRACE, & INLET/OUTLET	CAF	10/16/15
REV	DRAWING STATUS	BY	DATE



THIS DRAWING AND THE SOLUTIONS/DESIGNS ARE THE PROPERTY OF CAMCORP, INC. AND ARE FURNISHED ONLY FOR INFORMATIONAL PURPOSES ON A CONFIDENTIAL BASIS. REPRODUCTION, PUBLISHING, OR OTHER DISCLOSURES ARE ON A "NEED TO KNOW" BASIS ONLY. ANY OTHER REPRODUCTION REQUIRES WRITTEN AUTHORIZATION BY A CORPORATE OFFICER.

CERTIFIED FOR CONSTRUCTION PURPOSES DATE: 10/13/15 SIGNATURE: <i>John Adkins</i> CAMCORP, INC.	CUSTOMER:		
	TITLE: HE39 CYCLONE COLLECTOR		
	DRAWN: CAF	DATE: 10/7/15	P.O. NUMBER: REVISION: REV3
	JOB NUMBER:		DRAWING NUMBER:

IT IS THE CUSTOMERS RESPONSIBILITY TO NOTIFY CAMCORP IN WRITING IF THE DUST IS EXPLOSIVE, OR HAS EXPLOSIVE CHARACTERISTICS